

ICEA P-79-561

Guide for Selecting Aerial Cable Messengers and Lashing Wires

Published by

**Insulated Cable Engineers Association, Inc.
Post Office Box 1568
Carrollton, Georgia 30112, USA**

Approved by Insulated Cable Engineers Association, Inc.: 02/22/2008

Approved by ANSI: 12/30/2008

© Copyright 2008 by the Insulated Cable Engineers Association, Inc. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the international and Pan American Copyright Conventions.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The Insulated Cable Engineers Association, Inc. (ICEA) standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together persons who have an interest in the topic covered by this publication. While ICEA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

ICEA disclaims liability for personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. ICEA disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. ICEA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, ICEA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is ICEA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgement or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

ICEA has no power, nor does it undertake to police or enforce compliance with the contents of this document. ICEA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to ICEA and is solely the responsibility of the certifier or maker of the statement.

FOREWORD

This guide publication for selecting aerial cable messengers, ICEA P-79-561, was developed by the Insulated Cable Engineers Association (ICEA).

ICEA standards and guides are adopted in the public interest and are designed to eliminate misunderstanding between the manufacturer and the user and to assist the user in selecting and obtaining the proper product for his particular need. Existence of an ICEA/NEMA Standard does not in any respect preclude the manufacture or use of products not conforming to the standard. The user of this Standard is cautioned to observe any health or safety regulations and rules relative to the manufacture and use of cable made in conformity with this Standard.

Requests for interpretation of this Standard must be submitted in writing to:

Insulated Cable Engineers Association
Post Office Box 1568
Carrollton, Georgia 30112

An official written interpretation will be provided once approved by ICEA. Suggestions for improvements gained in the use of this Standard will be welcomed by the Association.

Page 16 (Figure 250-1 & Table 250-1) reprinted with permission from IEEE Std. C2 2007 National Electrical Safety Code, Copyright 2007, by IEEE. The IEEE disclaims any responsibility or liability resulting from the placement and use in the described manner.

Pages 21, 22 and 23 (Chart A-2, Chart B-2 & Sag Tables) reprinted with permission from Copperweld Bimetallics, LLC.

CONTENTS

	Page
FOREWORD.....	i
Section 1	1
GENERAL	1
1.1 SCOPE.....	1
1.2 UNITS.....	1
1.3 REFERENCES.....	1
Section 2	2
MESSENGERS AND LASHING WIRES	2
2.1 MESSENGER SELECTION.....	2
2.2 MESSENGER CHARACTERISTICS.....	2
2.3 MESSENGER AND LASHING WIRE SIZES.....	2
2.4 LASHING WIRE LAY LENGTHS	2
Section 3	3
SPAN LENGTHS	3
3.1 RECOMMENDED MAXIMUM SPAN LENGTHS.....	3
Section 4	15
SAG AND TENSION CALCULATIONS	15
4.1 SAG AND TENSION CALCULATIONS FOR AERIAL CABLES	15
4.2 ICE AND WIND LOADINGS	15
4.3 LOADING DISTRICT	15
4.4 EXAMPLE SAG AND TENSION CALCULATIONS FOR FACTORY-ASSEMBLED CABLE.....	17
4.5 EXAMPLE SAG AND TENSION CALCULATIONS FOR FIELD-ASSEMBLED CABLE.....	20
APPENDICES	24
APPENDIX A	24

Section 1

GENERAL

1.1 SCOPE

This guide has been prepared to facilitate the selection of messengers and lashing wires for both field and factory-assembled self-supporting aerial cables.

The cables used for attachment to the messenger shall be suitable for the service and shall be manufactured and tested in accordance with the applicable ICEA Standards and installed in accordance with the applicable provisions of the National Electrical Code (NFPA-70) and/or the National Electrical Safety Code/ANSI Standards Publication No. C2.

This guide does not cover all possible messenger configurations. Reference should be made to other publications for service drop and neutral supported applications.

1.2 UNITS

In this guide, units are expressed in the English system. To convert from an English unit to the appropriate metric unit, multiply the value of the English unit by the appropriate number from the following table:

<u>From</u>	<u>To</u>	<u>Multiplier</u>
inches (in.)	millimeters (mm)	25.4
ohms per 1000 feet ($\Omega/1000'$)	milliohms per meter ($m\Omega/m$)	3.28
square inch (sq. in.)	square millimeter (mm^2)	645
thousand circular mils (kcmil)	square millimeter (mm^2)	0.5067
pounds per square inch (psi)	kilopascals (kPa)	6.89
pounds per foot	newtons per meter	14.6

1.3 REFERENCES

See Appendix A for a complete list of referenced standards by title and date.